



patro + m.č.	teplota	vlhkost	vzduch - VAV	vzduch - VZ
1.NP - 1.15	15°C-18°C	50%-55%	85-850m3/h	150m3/h