



patro + m.č.	teplota	vlhkost	vzduch - VAV	vzduch - VZ
2.NP - 2.10	15°C-18°C	50%-55%	25-850m3/h	250m3/h
2.NP - 2.08	15°C-18°C	50%-55%	20-200m3/h	56m3/h