

# Navrh otopnych teles firmy K O R A D O a.s. Ceska Trebova

Akce : KSUSV Pribyslav  
Datum : 18. 6.2017

Teplota topne vody - privodni : 70.0 oC  
vratne : 55.0 oC  
Procento vykonu pro navrh teles : 100.0

Vypis pro okruh c. 1

Mistnost cislo popis	Soustava teplota oC oC/oC	Otopne teleso --	delka mm	vodni objem dm3	tepelny vykon W
101 spol. mistnost	22 70/55	22-060160-60-VK	1600	9.3	2006
102 chodba	18 70/55	11-050040-E0-VKL	400	1.1	293
103 susarna obuvi	22 70/55	21-050040-60-VK	400	2.0	335
104 satna	22 70/55	21-060100-60-VK	1000	5.8	963
105 koupelna	24 70/55	11-050070-60-VK	700	1.9	421
105 koupelna	24 70/55	KLCM1500.0450	450	5.7	425
106 wc	20 70/55	11-050040-60-VK	400	1.1	275

Otopne teleso --	vyska mm	delka mm	cena Kc/ks	Celkem pocet kusu	Celkem cena Kc	vodni objem dm3	tepelny vykon W
11-050040-60-VK	500	400	0	1	0	1.1	275
11-050070-60-VK	500	700	0	1	0	1.9	421
21-050040-60-VK	500	400	0	1	0	2.0	334
21-060100-60-VK	600	1000	0	1	0	5.8	962
22-060160-60-VK	600	1600	0	1	0	9.3	2005
11-050040-E0-VKL	500	400	0	1	0	1.1	292
KLCM1500.0450	1500	450	0	1	0	5.7	425
Celkem okruh c. 1				7	0	26.9	4714
Celkem objekt				7	0	26.9	4714