



patro + m.č.	teplota	vlhkost	vzduch - VAV	vzduch - VZ
2.NP - 2.13	15°C-18°C	50%-55%	75-750m3/h	100m3/h
2.NP - 2.26	15°C-18°C	50%-55%	15-150m3/h	30m3/h